



Arab Company الشركة العربية
For Laboratories & Soil للمختبرات و التربة

Fire Rating & Melting Point Report for Autoclaved Aerated Concrete Products

Owner	ESPAC	Report No.	KMR16000528
Project Name	Autoclaved Aerated Concrete Products testing	Date Reported	12-03-16
Request No.	KMQ000141	Sample No.	KMS16000182
Project No.	-	Client Reference	PO
Sample Description	Autoclaved Aerated Concrete Proucts	Sample Size	-
Specimen Preparation	ASTM E119	Date Tested	12-03-16
Test Method	ASTM E119	Tested By	Wasel

Sample No.	Test	Standard	Results	Thickness (cm)
1	Fire Rating	ASTM E119	6.4 hrs	20
2	Melting Point		1290 C	



Arab Company الشركة العربية
For Laboratories & Soil للمختبرات و التربة
C.R. 2051037267 ٢٠٥١٠٣٧٢٦٧

Rashad A. Al Kilani
Branch Manager
Arab Company for Laboratories & Soil

ACES Khobar: P.O.Box 70156 Al-Khobar 31952 - Tel:+966 (13) 881 1941 / 881 1942 - Fax:+966 (13) 881 1947 - C.C. No. 98216 - C.R. : 2051037267 - E-mail: aceskhobar@aces-int.com
ACES Riyadh: P.O.Box 46891 Riyadh 11542 - Tel:+966 (11) 237 2222 / 235 3467 - Fax:+966 (11) 235 7434 - C.C. No.116998- C.R. : 1010172258 - E-mail: acesriyadh@aces-int.com
ACES Jeddah: P.O.Box 132905 Jeddah 21382 - Tel:+966 (12) 664 1422, 663 6380 - Fax:+966 (12) 663 5448 - C.C. No. 106934 - C.R. : 4030147586 - E-mail: acesjeddah@aces-int.com
ACES Najran: P.O.Box 406 Najran - Tel:+966 (17) 523 9037 / 523 0273- Fax:+966 (17) 523 5761 - C.C. No. 1117678 - C.R. : 5950017513 - E-mail: acesnajran@aces-int.com
ACES Buraydah: P.O.Box 52391 Buraydah 8225 - Tel.:+966 (16) 384 4575 - Fax:+966 (16) 384 4001 - C.C. No. 601001156942 - C.R. : 1131032563 - E-mail: acesburaydah@aces-int.com

Website : www.aces-int.com



شركة ذات مسؤولية محدودة رأس المال ٣,٦٠٠,٠٠٠